






1" NOMINAL DIAM. OR
 EQUIVALENT BUTYL
 RUBBER MASTIC SEALANT
 CONTINUOUS IN JOINT



SIDE VIEW
 N.T.S.



SIDE VIEW
 N.T.S.



TOP VIEW
 N.T.S.

4" THICK
 WALLS
 4" POLYLOK CLOSED
 END BOOT (TYP.)

1,000 GALLON TANK

- NOTES:
1. CONCRETE: 5,000 PSI MIN. AFTER 28 DAYS
 2. ALL REINFORCEMENT PER ASTM C1227-93
 3. TEES AND GAS BAFFLE SOLD SEPARATELY
 4. TONGUE & GROOVE JOINT SEALED WITH BUTYL RESIN
 5. 4" POLYLOK IV CLOSED END BOOTS USED FOR CONNECTIONS.
 6. PLASTIC RISERS CAN BE POURED INTO COVER
 7. PUMPS & ACCESSORIES OPTIONAL



100 COACHECO RD.
 FARMINGTON, NH 03835
 OFFICE: (603) 755-2515
 FAX: (603) 278-7878

FOR: 1,000 TANK	
FILE NAME: 1000 TANK	DATE: JUNE 16, 2018
DRAWN BY: SO	