



- NOTES:
1. CONCRETE: 5,000PSI MIN AFTER 28 DAYS.
 2. ALL REINFORCEMENT PER ASTM C1227-93.
 3. TEES AND GAS BAFFLE SOLD SEPARATELY.
 4. TONGUE & GROOVE JOINT SEALED WITH BUTYLE RESIN.
 5. 4" POLYLOK IV CLOSED END BOOTS USED FOR CONNECTIONS.
 6. PLASTIC RISER CAN BE Poured INTO COVER.
 7. PUMPS & ACCESSORIES OPTIONAL.

REV. NO.		DATE	REVISION
PREPARED BY:		PREPARED FOR: ANDREW J. FOSS CO. INC. 100 COCHECO ROAD FARMINGTON, NH 03835 PHONE(603)755-2515 FAX(603)278-7878	
DATE: 9/17/09		SHEET TITLE: SKETCH	DRWN BY: GJP
SCALE: N.T.S.			CKD BY: KMK
PROJECT:		1250/350/500 GALLON TANK H-10	
CONTRACTOR:		DWG. I.D.	SK-01
DELTA PROJ. NO.: 2009.367.001		SHT. NO.	1 OF 1

DELTA
 ENGINEERS, ARCHITECTS, & LAND SURVEYORS
 184 COURT STREET, BINGHAMTON, NY 13901
 TEL: (607) 231-6600 FAX: (607) 231-6650