



- NOTES:
1. CONCRETE: 5,000PSI MIN AFTER 28 DAYS.
 2. ALL REINFORCEMENT PER ASTM C1227-93.
 3. TEES AND GAS BAFFLE SOLD SEPARATELY.
 4. TONGUE & GROOVE JOINT SEALED WITH BUTYLE RESIN.
 5. 4" POLYLOK IV CLOSED END BOOTS USED FOR CONNECTIONS.
 6. PLASTIC RISER CAN BE POURED INTO COVER.

			PREPARED FOR:	
			ANDREW J. FOSS CO. INC.	
			100 COCHECO ROAD	
			FARMINGTON, NH 03835	
			PHONE(603)755-2515 FAX(603)278-7878	
REV. NO.	DATE	REVISION		
PREPARED BY:			DATE: 9/16/09	SHEET TITLE: SKETCH
DELTA ENGINEERS, ARCHITECTS, & LAND SURVEYORS 184 COURT STREET, BINGHAMTON, NY 13901 TEL: (607) 231-6800 FAX: (607) 231-6850			DRWN BY: GJP	CRD BY: KMK
			SCALE: N.T.S.	PROJECT: 5000 GALLON TANK H-20
			CONTRACTOR:	DWG. I.D. SK-01
			DELTA PROJ. NO.: 2009.367.001	SHT. NO. 1 OF 1