



NOTES:

1. CONCRETE: 5,000 PSI MIN AFTER 28 DAYS.
2. TYPE III CEMENT.
3. TEST BAFFLES SOLD SEPARATELY.
4. 4" POLYLOK IV CLOSED END BOOTS USED FOR CONNECTIONS.
5. JOINT SEALED WITH BUTYLE RESIN.
6. PUMPS & ACCESSORIES OPTIONAL
7. PLASTIC RISER CAN BE POURED INTO COVER.

				PREPARED FOR: ANDREW J. FOSS CO. INC. 100 COCHECO ROAD FARMINGTON, NH 03835 PHONE(603)755-2515 FAX(603)278-7878	
				DATE: 9/18/09 SCALE: N.T.S.	SHEET TITLE: SKETCH
				PROJECT: 600 GALLON PUMP BOX 6'-4"x6'-4"x4'-6" H-20	
				CONTRACTOR: DELTA PROJ. NO.: 2009.367.001	DRAWN BY: GJP CKD BY: KMK DWG. I.D. SK-01 SHI. NO. 1 OF 1
REV. NO. DATE REVISION			PREPARED BY: <div style="text-align: center;"> <p>DELTA ENGINEERS, ARCHITECTS, & LAND SURVEYORS 184 COURT STREET, BINGHAMTON, NY 13901 TEL: (607) 231-6600 FAX: (607) 231-6650</p> </div>		