



Surveyors & Septic Designers, Inc

301 North Main Street, Suite 1
Barre, VT 05641

WILLIAM R. (BILL) CHASE, PLS

CRAIG D. CHASE (SEPTIC DESIGNER)

ASSOCIATES: KRIS JURENTKUFF, ROBERT BROWN

Phone 802-479-9636

Fax 802-479-4017

E-mail BillChase@chasesurveyors.com

E-mail CDChase@chasesurveyors.com

E-mail: KJurentkuff@chasesurveyors.com

October 14, 2016

Carl Fuller P.E.

Regional Engineer

Agency of Natural Resources

Department of Environmental Conservation

Drinking Water & Groundwater Protection Division

Montpelier Regional Office

1 National Life Drive, Davis 1

Montpelier VT 05620-3703

Re: Installation certification, WW-5-6225, Murray, _____ East Montpelier

Dear Carl,

On a few occasions this month, the installation of the wastewater system and potable water supply permitted in WW-5-6225 was inspected. Based on what was visually available for me to see at the time of inspections, which was limited to the wellhead location (tag# 56582), the exposed tops and interiors of the Norweco processor and pump station, the at-grade bed with stone and distribution laterals which had been staked out by my firm, the plowed surface, the forcemain pressure test, a system distribution spray test and final grading.

Based solely on what was readily visually accessible at the time our presence was requested for inspection, I hereby certify that in the exercise of my reasonable professional judgment the installation-related information submitted is true and correct and that the wastewater system and potable water system components exposed were installed in accordance with the permitted design and all permit conditions, were inspected, were properly tested, and have successfully met those performance tests.

See also the attached Norweco start up report.

Sincerely,

Craig Chase

Certified Septic Designer B+ #371VT