



PSNH CONCRETE PULLBOX
(FOR GRASSY AREAS ONLY, H-10 LOADING)



PLAN VIEW

Note: Pulling Eye to be 3/4" X 8" Galvanized Eyebolt with 2" Eye. Eyebolt to extend through wall with a 6" galvanized steel washer on both sides and fastened on the outside with a 2" galvanized steel nut or equivalent. One opposite each knockout. Lifting hooks (4) to be #6 ASTM-615 reinforcement. Knockouts to be sufficient for 5" schedule 40 conduit. Weight: top 2,700 lbs., bottom 5,000 lbs.



PROFILE VIEW

ISSUE	DATE
Original	12/2/98
Rev	11/6/00

CONSTRUCTION REQUIREMENT

Public Service
of New Hampshire

