



- NOTES:
1. CONCRETE: 5,000 PSI MIN AFTER 28 DAYS.
 2. TYPE III CEMENT.
 3. TEST BAFFLES SOLD SEPARATELY.
 4. 4" POLYLOK IV CLOSED END BOOTS USED FOR CONNECTIONS.
 5. JOINT SEALED WITH BUTYLE RESIN.
 6. PUMPS & ACCESSORIES OPTIONAL
 7. PLASTIC RISER CAN BE POURED INTO COVER.

PREPARED FOR: ANDREW J. FOSS CO. INC. 100 COCHECO ROAD FARMINGTON, NH 03835 PHONE(603)755-2515 FAX(603)278-7878		
DATE: 9/18/09 SCALE: N.T.S.	SHEET TITLE: SKETCH	DRWN BY: GJP CKD BY: KMK
PROJECT: 4' x 4' HD PUMP BOX		
CONTRACTOR: DELTA PROJ. NO.: 2009.367.001		DWG. I.D. SK-01 SH. NO. 1 OF 1

REV. NO.	DATE	REVISION

PREPARED BY:
DELTA
 ENGINEERS, ARCHITECTS, & LAND SURVEYORS
 184 COURT STREET, BINGHAMTON, NY 13901
 TEL: (607) 231-6600 FAX: (607) 231-6650