



SECTION VIEW  
 N.T.S.



END VIEW  
 N.T.S.

- NOTES:
1. CONCRETE: 5,000 PSI MIN. AFTER 28 DAYS
  2. ALL REINFORCEMENT PER ASTM C1227-93
  3. TEES AND GAS BAFFLE SOLD SEPARATELY
  4. TONGUE & GROOVE JOINT SEALED WITH BUTYL RESIN
  5. 4" POLYLOK IV CLOSED END BOOTS USED FOR CONNECTIONS.
  6. PLASTIC RISERS CAN BE POURED INTO COVER
  7. PUMPS & ACCESSORIES OPTIONAL



TOP VIEW  
 N.T.S.

**1,600 MONO TANK**  
**SINGLE COMPARTMENT**

**AJ FOSS**  
 The Signature of Quality Precast™

100 COACHECO RD.  
 FARMINGTON, NH 03835  
 OFFICE: (603) 755-2515  
 FAX: (603) 278-7878

1,600 MONO TANK	
FOR: AJ FOSS 100 COACHECO ROAD FARMINGTON, NH 03835 FAX: (603) 278-7878	DATE: FEB 11, 2016
	FILE NAME: 1600 MONO
	DRAWN BY: SO