



## Three Phase Sector Cabinet Foundation



REINFORCING SCHEDULE (#6 BAR)			
Type	Qty	Length	Diagram
U1	4	132"	

Total Foundation Weight, 3,600 lbs.

EVERSOURCE INTERNAL REFERENCE 53.128

Refer to [Installation Requirements for Padmounted Transformer and Sector Cabinets](#) for additional details.